

**BKROC.R25807
Composite Panels**[Page Bottom](#)**Composite Panels**[See General Information for Composite Panels](#)**NORBEC ARCHITECTURAL**

R25807

97 DE VAUDREUIL

BOUCHERVILLE, QC J4B 1K7 CANADA

Composite building panels comprised of polyisocyanurate foam, expanded polystyrene foam, or mineral wool core clad on both sides with a pre-painted sheet steel skin.

Finished panels Listed as to surface burning characteristics in accordance with CAN/ULC-S102 as indicated.

"Norex" and "Noroc" core material Listed as to surface burning characteristics in accordance with CAN/ULC-S102 as indicated.

"Norlam" core material Listed as to surface burning characteristics in accordance with CAN/ULC-S102.2 as indicated.

Material Details	Classification or Rating	
	Flame Spread	Smoke Developed
"NOREX-L" finished panel, 150 mm thick max	15	285
Core material, 150 mm thick max	440	150
"NOREX-S" finished panel, 127 mm thick max	15	165
Core material, 150 mm thick max	440	150
"NOREX-H" finished panel, 100 mm thick max	10	180
Core material, 150 mm thick max	440	150
"NORLAM" finished panel, 300 mm thick max	90	440
Core material, 300 mm thick max	290	Over 670
"NOROC-L" finished panel, 100 - 150 mm thick	25	45
Core material, 150 mm thick max	0	0

[Last Updated](#) on 2012-03-27[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

Copyright © 2012 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2012 Underwriters Laboratories of Canada Inc."